

Mr. David Miller
Isle Public School
Post Office Box 25
Isle, Minnesota 56342

Re: Compliance Evaluation Inspection

Dear Mr. Miller:

On October 18, 2016, a representative of the U.S. Environmental Protection Agency inspected the Isle School Bus Garage, located in Isle, Minnesota. The purpose of the inspection was to evaluate the facility's compliance with certain requirements of the Resource Conservation and Recovery Act (RCRA), specifically the technical standards and corrective action requirements for owners and operators of underground storage tanks set forth at 40 Code of Federal Regulations Part 280. Enclosed please find a copy of our inspection report dated October 18, 2016.

Based upon the information available to the EPA, the inspection did not detect any violations of the specific RCRA requirements under evaluation. This determination does not limit the applicability of the requirements evaluated, other RCRA regulations, or regulations under other environmental statutes. The EPA will continue to evaluate your facility in the future.

The inspector noted that there was a damaged rubber seal at the electrical box on the wire from the automatic tank gauge sensor. While this is not a violation it is recommended that this be fixed as soon as possible. If not repaired it could damage the sensor.

If you have any questions or concerns regarding this matter, please contact Mark Restaino, of my staff, at 312-886-0394.

Sincerely,

Gary J. Victorine, Chief
RCRA Branch

Enclosure

cc: Ryan Rupp, Department of Natural Resources, Mille Lacs Band of Ojibwe Indians
Andrew Boyd, Department of Natural Resources, Mille Lacs Band of Ojibwe Indians